

# FEDERAL OPERATING PERMIT

A FEDERAL OPERATING PERMIT IS HEREBY ISSUED TO  
Florida Gas Transmission Company, LLC

AUTHORIZING THE OPERATION OF  
Vidor Compressor Station  
Natural Gas Transmission

LOCATED AT  
Orange County, Texas  
Latitude 30° 4' 12" Longitude 93° 57' 7"  
Regulated Entity Number: RN100227909

This permit is issued in accordance with and subject to the Texas Clean Air Act (TCAA), Chapter 382 of the Texas Health and Safety Code and Title 30 Texas Administrative Code Chapter 122 (30 TAC Chapter 122), Federal Operating Permits. Under 30 TAC Chapter 122, this permit constitutes the permit holder's authority to operate the site and emission units listed in this permit. Operations of the site and emission units listed in this permit are subject to all additional rules or amended rules and orders of the Commission pursuant to the TCAA.

This permit does not relieve the permit holder from the responsibility of obtaining New Source Review authorization for new, modified, or existing facilities in accordance with 30 TAC Chapter 116, Control of Air Pollution by Permits for New Construction or Modification.

The site and emission units authorized by this permit shall be operated in accordance with 30 TAC Chapter 122, the general terms and conditions, special terms and conditions, and attachments contained herein.

This permit shall expire five years from the date of issuance. The renewal requirements specified in 30 TAC § 122.241 must be satisfied in order to renew the authorization to operate the site and emission units.

Permit No:     O3535     Issuance Date: \_\_\_\_\_

\_\_\_\_\_  
For the Commission

## Table of Contents

Section	Page
General Terms and Conditions .....	1
Special Terms and Conditions: .....	1
Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting.....	1
Additional Monitoring Requirements .....	5
New Source Review Authorization Requirements .....	5
Compliance Requirements.....	6
Permit Location .....	8
Permit Shield (30 TAC § 122.148) .....	8
Attachments .....	9
Applicable Requirements Summary.....	10
Additional Monitoring Requirements .....	21
Permit Shield.....	27
New Source Review Authorization References .....	30
Appendix A.....	33
Acronym List .....	34

## **General Terms and Conditions**

The permit holder shall comply with all terms and conditions contained in 30 TAC § 122.143 (General Terms and Conditions), 30 TAC § 122.144 (Recordkeeping Terms and Conditions), 30 TAC § 122.145 (Reporting Terms and Conditions), and 30 TAC § 122.146 (Compliance Certification Terms and Conditions).

In accordance with 30 TAC § 122.144(1), records of required monitoring data and support information required by this permit, or any applicable requirement codified in this permit, are required to be maintained for a period of five years from the date of the monitoring report, sample, or application unless a longer data retention period is specified in an applicable requirement. The five year record retention period supersedes any less stringent retention requirement that may be specified in a condition of a permit identified in the New Source Review Authorization attachment.

If the permit holder chooses to demonstrate that this permit is no longer required, a written request to void this permit shall be submitted to the Texas Commission on Environmental Quality (TCEQ) by the Responsible Official in accordance with 30 TAC § 122.161(e). The permit holder shall comply with the permit's requirements, including compliance certification and deviation reporting, until notified by the TCEQ that this permit is voided.

The permit holder shall comply with 30 TAC Chapter 116 by obtaining a New Source Review authorization prior to new construction or modification of emission units located in the area covered by this permit.

All reports required by this permit must include in the submittal a cover letter which identifies the following information: company name, TCEQ regulated entity number, air account number (if assigned), site name, area name (if applicable), and Air Permits Division permit number(s).

## **Special Terms and Conditions:**

### **Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting**

1. Permit holder shall comply with the following requirements:
  - A. Emission units (including groups and processes) in the Applicable Requirements Summary attachment shall meet the limitations, standards, equipment specifications, monitoring, recordkeeping, reporting, testing, and other requirements listed in the Applicable Requirements Summary attachment to assure compliance with the permit.
  - B. The textual description in the column titled "Textual Description" in the Applicable Requirements Summary attachment is not enforceable and is not deemed as a substitute for the actual regulatory language. The Textual Description is provided for information purposes only.
  - C. A citation listed on the Applicable Requirements Summary attachment, which has a notation [G] listed before it, shall include the referenced section and subsection for all commission rules, or paragraphs for all federal and state regulations and all subordinate paragraphs, subparagraphs and clauses, subclauses, and items contained within the referenced citation as applicable requirements.
  - D. When a grouped citation, notated with a [G] in the Applicable Requirements Summary, contains multiple compliance options, the permit holder must keep records of when each compliance option was used.

- E. Emission units subject to 40 CFR Part 63, Subpart ZZZZ as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, § 113.1090 which incorporates the 40 CFR Part 63 Subpart by reference.
2. The permit holder shall comply with the following sections of 30 TAC Chapter 101 (General Air Quality Rules):
- A. Title 30 TAC § 101.1 (relating to Definitions), insofar as the terms defined in this section are used to define the terms used in other applicable requirements
  - B. Title 30 TAC § 101.3 (relating to Circumvention)
  - C. Title 30 TAC § 101.8 (relating to Sampling), if such action has been requested by the TCEQ
  - D. Title 30 TAC § 101.9 (relating to Sampling Ports), if such action has been requested by the TCEQ
  - E. Title 30 TAC § 101.10 (relating to Emissions Inventory Requirements)
  - F. Title 30 TAC § 101.201 (relating to Emission Event Reporting and Recordkeeping Requirements)
  - G. Title 30 TAC § 101.211 (relating to Scheduled Maintenance, Start-up, and Shutdown Reporting and Recordkeeping Requirements)
  - H. Title 30 TAC § 101.221 (relating to Operational Requirements)
  - I. Title 30 TAC § 101.222 (relating to Demonstrations)
  - J. Title 30 TAC § 101.223 (relating to Actions to Reduce Excessive Emissions)
3. Permit holder shall comply with the following requirements of 30 TAC Chapter 111:
- A. Visible emissions from stationary vents with a flow rate of less than 100,000 actual cubic feet per minute and constructed after January 31, 1972 that are not listed in the Applicable Requirements Summary attachment for 30 TAC Chapter 111, Subchapter A, Division 1, shall not exceed 20% opacity averaged over a six-minute period. The permit holder shall comply with the following requirements for stationary vents at the site subject to this standard:
    - (i) Title 30 TAC § 111.111(a)(1)(B) (relating to Requirements for Specified Sources)
    - (ii) Title 30 TAC § 111.111(a)(1)(E)
    - (iii) Title 30 TAC § 111.111(a)(1)(F)(i), (ii), (iii), or (iv)
    - (iv) For emission units with vent emissions subject to 30 TAC § 111.111(a)(1)(B), complying with 30 TAC § 111.111(a)(1)(F)(ii), (iii), or (iv), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO<sub>x</sub>, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146. These periodic monitoring requirements do not apply to vents that are not capable of producing visible emissions such as vents that emit only colorless VOCs; vents from non-fuming liquids; vents that provide passive

ventilation, such as plumbing vents; or vent emissions from any other source that does not obstruct the transmission of light. Vents, as specified in the "Applicable Requirements Summary" attachment, that are subject to the emission limitation of 30 TAC § 111.111(a)(1)(B) are not subject to the following periodic monitoring requirements:

- (1) An observation of stationary vents from emission units in operation shall be conducted at least once during each calendar quarter unless the emission unit is not operating for the entire quarter.
- (2) For stationary vents from a combustion source, if an alternative to the normally fired fuel is fired for a period greater than or equal to 24 consecutive hours, the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are present. If such period is greater than 3 months, observations shall be conducted once during each quarter. Supplementing the normally fired fuel with natural gas or fuel gas to increase the net heating value to the minimum required value does not constitute creation of an alternative fuel.
- (3) Records of all observations shall be maintained.
- (4) Visible emissions observations of emission units operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of emission units operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions observations shall be made during times when the activities described in 30 TAC § 111.111(a)(1)(E) are not taking place. Visible emissions shall be determined with each stationary vent in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each stationary vent during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.
- (5) Compliance Certification:
  - (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(1) and (a)(1)(B).
  - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(1)(F) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity

requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

- (c) Some vents may be subject to multiple visible emission or monitoring requirements. All credible data must be considered when certifying compliance with this requirement even if the observation or monitoring was performed to demonstrate compliance with a different requirement.

B. Emission limits on nonagricultural processes, except for the steam generators specified in 30 TAC § 111.153, shall comply with the following requirements:

- (i) Emissions of PM from any source may not exceed the allowable rates as required in 30 TAC § 111.151(a) (relating to Allowable Emissions Limits)
- (ii) Sources with an effective stack height ( $h_e$ ) less than the standard effective stack height ( $H_e$ ), must reduce the allowable emission level by multiplying it by  $[h_e/H_e]^2$  as required in 30 TAC § 111.151(b)
- (iii) Effective stack height shall be calculated by the equation specified in 30 TAC § 111.151(c)

4. Permit holder shall comply with the following 30 TAC Chapter 115, Subchapter C requirements:

A. When filling stationary gasoline storage vessels (Stage I) for motor vehicle fuel dispensing facilities, constructed prior to November 15, 1992, with transfers to stationary storage tanks located at a facility which has dispensed no more than 10,000 gallons of gasoline in any calendar month after January 1, 1991, the permit holder shall comply with the following requirements specified in 30 TAC Chapter 115, Subchapter C:

- (i) Title 30 TAC § 115.222(3) (relating to Control Requirements), as it applies to liquid gasoline leaks, visible vapors, or significant odors
- (ii) Title 30 TAC § 115.222(6) (relating to Control Requirements)
- (iii) Title 30 TAC § 115.224(1) (relating to Inspection Requirements), as it applies to liquid gasoline leaks, visible vapors, or significant odors
- (iv) Title 30 TAC § 115.226(2)(B) (relating to Recordkeeping Requirements)

5. The permit holder shall comply with the following requirements for units subject to any subpart of 40 CFR Part 60, unless otherwise stated in the applicable subpart:

- A. Title 40 CFR § 60.7 (relating to Notification and Recordkeeping)
- B. Title 40 CFR § 60.8 (relating to Performance Tests)
- C. Title 40 CFR § 60.11 (relating to Compliance with Standards and Maintenance Requirements)

- D. Title 40 CFR § 60.12 (relating to Circumvention)
  - E. Title 40 CFR § 60.13 (relating to Monitoring Requirements)
  - F. Title 40 CFR § 60.14 (relating to Modification)
  - G. Title 40 CFR § 60.15 (relating to Reconstruction)
  - H. Title 40 CFR § 60.19 (relating to General Notification and Reporting Requirements)
6. The permit holder shall comply with the requirements of 30 TAC Chapter 113, Subchapter C, § 113.100 for units subject to any subpart of 40 CFR Part 63, unless otherwise stated in the applicable subpart.
  7. The permit holder shall comply with certified registrations submitted to the TCEQ for purposes of establishing federally enforceable emission limits. A copy of the certified registration shall be maintained with the permit. Records sufficient to demonstrate compliance with the established limits shall be maintained. The certified registration and records demonstrating compliance shall be provided, on request, to representatives of the appropriate TCEQ regional office and any local air pollution control agency having jurisdiction over the site. The permit holder shall submit updated certified registrations when changes at the site require establishment of new emission limits. If changes result in emissions that do not remain below major source thresholds, the permit holder shall submit a revision application to codify the appropriate requirements in the permit.

#### **Additional Monitoring Requirements**

8. The permit holder shall comply with the periodic monitoring requirements as specified in the attached "Periodic Monitoring Summary" upon issuance of the permit. Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the permit holder shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit is operating. The permit holder may elect to collect monitoring data on a more frequent basis and average the data, consistent with the averaging time specified in the "Periodic Monitoring Summary," for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis. In no event shall data be collected and used in particular instances to avoid reporting deviations. Deviations shall be reported according to 30 TAC § 122.145 (Reporting Terms and Conditions).

#### **New Source Review Authorization Requirements**

9. Permit holder shall comply with the requirements of New Source Review authorizations issued or claimed by the permit holder for the permitted area, including permits, permits by rule, standard permits, flexible permits, special permits, permits for existing facilities including Voluntary Emissions Reduction Permits and Electric Generating Facility Permits issued under 30 TAC Chapter 116, Subchapter I, or special exemptions referenced in the New Source Review Authorization References attachment. These requirements:
  - A. Are incorporated by reference into this permit as applicable requirements
  - B. Shall be located with this operating permit
  - C. Are not eligible for a permit shield

10. The permit holder shall comply with the general requirements of 30 TAC Chapter 106, Subchapter A or the general requirements, if any, in effect at the time of the claim of any PBR.
11. The permit holder shall maintain records to demonstrate compliance with any emission limitation or standard that is specified in a permit by rule (PBR) or Standard Permit listed in the New Source Review Authorizations attachment. The records shall yield reliable data from the relevant time period that are representative of the emission unit's compliance with the PBR or Standard Permit. These records may include, but are not limited to, production capacity and throughput, hours of operation, safety data sheets (SDS), chemical composition of raw materials, speciation of air contaminant data, engineering calculations, maintenance records, fugitive data, performance tests, capture/control device efficiencies, direct pollutant monitoring (CEMS, COMS, or PEMS), or control device parametric monitoring. These records shall be made readily accessible and available as required by 30 TAC § 122.144. Any monitoring or recordkeeping data indicating noncompliance with the PBR or Standard Permit shall be considered and reported as a deviation according to 30 TAC § 122.145 (Reporting Terms and Conditions).
12. The permit holder shall comply with the following requirements for Air Quality Standard Permits:
  - A. Registration requirements listed in 30 TAC § 116.611, unless otherwise provided for in an Air Quality Standard Permit
  - B. General Conditions listed in 30 TAC § 116.615, unless otherwise provided for in an Air Quality Standard Permit
  - C. Applicable requirements of 30 TAC § 116.620 for Installation and/or Modification of Oil and Gas Facilities based on the information contained in the registration application.

#### **Compliance Requirements**

13. The permit holder shall certify compliance in accordance with 30 TAC § 122.146. The permit holder shall comply with 30 TAC § 122.146 using at a minimum, but not limited to, the continuous or intermittent compliance method data from monitoring, recordkeeping, reporting, or testing required by the permit and any other credible evidence or information. The certification period may not exceed 12 months and the certification must be submitted within 30 days after the end of the period being certified.
14. Permit holder shall comply with the following 30 TAC Chapter 117 requirements:
  - A. The permit holder shall comply with the compliance schedules and submit written notification to the TCEQ Executive Director as required in 30 TAC Chapter 117, Subchapter H, Division 1:
    - (i) For sources in the Beaumont-Port Arthur Nonattainment area, 30 TAC § 117.9000
  - B. The permit holder shall comply with the Initial Control Plan unit listing requirement in 30 TAC § 117.150(c) and (c)(1).
15. Use of Emission Credits to comply with applicable requirements:
  - A. Unless otherwise prohibited, the permit holder may use emission credits to comply with the following applicable requirements listed elsewhere in this permit:
    - (i) Title 30 TAC Chapter 115



- (ii) Title 30 TAC Chapter 117
    - (iii) Offsets for Title 30 TAC Chapter 116
  - B. The permit holder shall comply with the following requirements in order to use the emission credits to comply with the applicable requirements:
    - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.306(c)-(d)
    - (ii) The emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 1
    - (iii) The executive director has approved the use of the credit according to 30 TAC § 101.306(c)-(d)
    - (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.302(g) and 30 TAC Chapter 122
    - (v) Title 30 TAC § 101.305 (relating to Emission Reductions Achieved Outside the United States)
16. Use of Discrete Emission Credits to comply with the applicable requirements:
- A. Unless otherwise prohibited, the permit holder may use discrete emission credits to comply with the following applicable requirements listed elsewhere in this permit:
    - (i) Title 30 TAC Chapter 115
    - (ii) Title 30 TAC Chapter 117
    - (iii) If applicable, offsets for Title 30 TAC Chapter 116
    - (iv) Temporarily exceed state NSR permit allowables
  - B. The permit holder shall comply with the following requirements in order to use the credit to comply with the applicable requirements:
    - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.376(d)
    - (ii) The discrete emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 4
    - (iii) The executive director has approved the use of the discrete emission credits according to 30 TAC § 101.376(d)(1)(A)
    - (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.372(h) and 30 TAC Chapter 122
    - (v) Title 30 TAC § 101.375 (relating to Emission Reductions Achieved Outside the United States)

**Permit Location**

17. The permit holder shall maintain a copy of this permit and records related to requirements listed in this permit at the Cypress Compressor Station, 15528 Huffmeister Road, Cypress, Texas, 77429.

**Permit Shield (30 TAC § 122.148)**

18. A permit shield is granted for the emission units, groups, or processes specified in the attached "Permit Shield." Compliance with the conditions of the permit shall be deemed compliance with the specified potentially applicable requirements or specified potentially applicable state-only requirements listed in the attachment "Permit Shield." Permit shield provisions shall not be modified by the executive director until notification is provided to the permit holder. No later than 90 days after notification of a change in a determination made by the executive director, the permit holder shall apply for the appropriate permit revision to reflect the new determination. Provisional terms are not eligible for this permit shield. Any term or condition, under a permit shield, shall not be protected by the permit shield if it is replaced by a provisional term or condition or the basis of the term and condition changes.

## **Attachments**

**Applicable Requirements Summary**

**Additional Monitoring Requirements**

**Permit Shield**

**New Source Review Authorization References**

### **Applicable Requirements Summary**

<b>Unit Summary .....</b>	<b>11</b>
---------------------------	-----------

<b>Applicable Requirements Summary .....</b>	<b>13</b>
--	-----------

Note: A “none” entry may be noted for some emission sources in this permit’s “Applicable Requirements Summary” under the heading of “Monitoring and Testing Requirements” and/or “Recordkeeping Requirements” and/or “Reporting Requirements.” Such a notation indicates that there are no requirements for the indicated emission source as identified under the respective column heading(s) for the stated portion of the regulation when the emission source is operating under the conditions of the specified SOP Index Number. However, other relevant requirements pursuant to 30 TAC Chapter 122 including Recordkeeping Terms and Conditions (30 TAC § 122.144), Reporting Terms and Conditions (30 TAC § 122.145), and Compliance Certification Terms and Conditions (30 TAC § 122.146) continue to apply.

### Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
601	Emission Points/Stationary Vents/Process Vents	N/A	R1111-ENG1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
601	SRIC Engines	N/A	R7201-ENG1	30 TAC Chapter 117, Subchapter B	No changing attributes.
602	Emission Points/Stationary Vents/Process Vents	N/A	R1111-ENG1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
602	SRIC Engines	N/A	R7201-ENG1	30 TAC Chapter 117, Subchapter B	No changing attributes.
603	Emission Points/Stationary Vents/Process Vents	N/A	R1111-ENG1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
603	SRIC Engines	N/A	R7201-ENG1	30 TAC Chapter 117, Subchapter B	No changing attributes.
ACOMP	Emission Points/Stationary Vents/Process Vents	N/A	R1111-ENG3	30 TAC Chapter 111, Visible Emissions	No changing attributes.
ACOMP	SRIC Engines	N/A	60JJJJ-ENG3	40 CFR Part 60, Subpart JJJJ	No changing attributes.
ACOMP	SRIC Engines	N/A	63ZZZZ-ENG3	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
G-1	Emission Points/Stationary Vents/Process Vents	N/A	R1111-ENG2	30 TAC Chapter 111, Visible Emissions	No changing attributes.
G-1	SRIC Engines	N/A	63ZZZZ-ENG2	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
LOAD	Loading/Unloading Operations	N/A	R115-LOAD1	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
LOAD-4A	Loading/Unloading Operations	N/A	R115-LOAD5	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
TK-1	Emission Points/Stationary Vents/Process Vents	N/A	R1111-TNK1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
TK-1	Storage Tanks/Vessels	N/A	R115-TK1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
TK-2	Storage Tanks/Vessels	N/A	R115-TK2	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
TK-5	Storage Tanks/Vessels	N/A	R115-TK5	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
TK-6	Storage Tanks/Vessels	N/A	R115-TK6	30 TAC Chapter 115, Storage of VOCs	No changing attributes.

### Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
TK-7	Storage Tanks/Vessels	N/A	R115-TK7	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
TK-9	Storage Tanks/Vessels	N/A	R115-TK9	30 TAC Chapter 115, Storage of VOCs	No changing attributes.

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
601	EP	R1111-ENG1	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(A) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 30% averaged over a six minute period.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
601	EU	R7201-ENG1	NO <sub>x</sub>	30 TAC Chapter 117, Subchapter B	§ 117.105(e) § 117.105(a) § 117.105(e)(1) § 117.130(a) § 117.130(d) § 117.130(d)(7) § 117.140(k) § 117.140(l)	No person shall allow the discharge into the atmosphere from any gas-fired, lean-burn, stationary, reciprocating internal combustion engine rated 300 hp or greater, NO <sub>x</sub> emissions in excess of 3.0 g/hp-hr.	[G]§ 117.135(a)(1) § 117.135(a)(4) § 117.135(b) § 117.135(d) § 117.135(e) § 117.135(g) § 117.140(a) § 117.140(g) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)	§ 117.145(a) § 117.145(f) § 117.145(f)(1) [G]§ 117.145(f)(3) § 117.145(f)(9)	§ 117.135(b) § 117.135(g) [G]§ 117.145(b) [G]§ 117.145(c) [G]§ 117.145(e) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
601	EU	R7201-ENG1	CO	30 TAC Chapter 117, Subchapter B	§ 117.105(e) § 117.105(a) § 117.105(e)(1) § 117.130(a) § 117.140(k)	No person shall allow the discharge into the atmosphere from any gas-fired, lean-burn, stationary, reciprocating internal combustion engine rated 300 hp or greater, CO emissions in excess of 3.0 g/hp-hr, as specified in §§117.105(e)(1)-(e)(2).	[G]§ 117.135(a)(1) § 117.135(a)(4) § 117.135(b) § 117.135(d) § 117.135(e) § 117.135(g) § 117.140(a) § 117.140(g) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3)	§ 117.145(a) § 117.145(f) § 117.145(f)(1) [G]§ 117.145(f)(3) § 117.145(f)(9)	§ 117.135(b) § 117.135(g) [G]§ 117.145(b) [G]§ 117.145(c) [G]§ 117.145(e) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)		[G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
602	EP	R1111-ENG1	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(A) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 30% averaged over a six minute period.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
602	EU	R7201-ENG1	NO <sub>x</sub>	30 TAC Chapter 117, Subchapter B	§ 117.105(e) § 117.105(a) § 117.105(e)(1) § 117.130(a) § 117.130(d) § 117.130(d)(7) § 117.140(k) § 117.140(l)	No person shall allow the discharge into the atmosphere from any gas-fired, lean-burn, stationary, reciprocating internal combustion engine rated 300 hp or greater, NO <sub>x</sub> emissions in excess of 3.0 g/hp-hr.	[G]§ 117.135(a)(1) § 117.135(a)(4) § 117.135(b) § 117.135(d) § 117.135(e) § 117.135(g) § 117.140(a) § 117.140(g) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)	§ 117.145(a) § 117.145(f) § 117.145(f)(1) [G]§ 117.145(f)(3) § 117.145(f)(9)	§ 117.135(b) § 117.135(g) [G]§ 117.145(b) [G]§ 117.145(c) [G]§ 117.145(e) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
602	EU	R7201-ENG1	CO	30 TAC Chapter 117, Subchapter B	§ 117.105(e) § 117.105(a) § 117.105(e)(1)	No person shall allow the discharge into the atmosphere from any gas-fired, lean-burn,	[G]§ 117.135(a)(1) § 117.135(a)(4) § 117.135(b)	§ 117.145(a) § 117.145(f) § 117.145(f)(1)	§ 117.135(b) § 117.135(g) [G]§ 117.145(b)



### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 117.130(a) § 117.140(k)	stationary, reciprocating internal combustion engine rated 300 hp or greater, CO emissions in excess of 3.0 g/hp-hr, as specified in §§117.105(e)(1)-(e)(2).	§ 117.135(d) § 117.135(e) § 117.135(g) § 117.140(a) § 117.140(g) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)	[G]§ 117.145(f)(3) § 117.145(f)(9)	[G]§ 117.145(c) [G]§ 117.145(e) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
603	EP	R1111-ENG1	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(A) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 30% averaged over a six minute period.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
603	EU	R7201-ENG1	NO <sub>x</sub>	30 TAC Chapter 117, Subchapter B	§ 117.105(e) § 117.105(a) § 117.105(e)(1) § 117.130(a) § 117.130(d) § 117.130(d)(7) § 117.140(k) § 117.140(l)	No person shall allow the discharge into the atmosphere from any gas-fired, lean-burn, stationary, reciprocating internal combustion engine rated 300 hp or greater, NO <sub>x</sub> emissions in excess of 3.0 g/hp-hr.	[G]§ 117.135(a)(1) § 117.135(a)(4) § 117.135(b) § 117.135(d) § 117.135(e) § 117.135(g) § 117.140(a) § 117.140(g) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)	§ 117.145(a) § 117.145(f) § 117.145(f)(1) [G]§ 117.145(f)(3) § 117.145(f)(9)	§ 117.135(b) § 117.135(g) [G]§ 117.145(b) [G]§ 117.145(c) [G]§ 117.145(e) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)		§ 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
603	EU	R7201-ENG1	CO	30 TAC Chapter 117, Subchapter B	§ 117.105(e) § 117.105(a) § 117.105(e)(1) § 117.130(a) § 117.140(k)	No person shall allow the discharge into the atmosphere from any gas-fired, lean-burn, stationary, reciprocating internal combustion engine rated 300 hp or greater, CO emissions in excess of 3.0 g/hp-hr, as specified in §§117.105(e)(1)-(e)(2).	[G]§ 117.135(a)(1) § 117.135(a)(4) § 117.135(b) § 117.135(d) § 117.135(e) § 117.135(g) § 117.140(a) § 117.140(g) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)	§ 117.145(a) § 117.145(f) § 117.145(f)(1) [G]§ 117.145(f)(3) § 117.145(f)(9)	§ 117.135(b) § 117.135(g) [G]§ 117.145(b) [G]§ 117.145(c) [G]§ 117.145(e) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
ACOMP	EP	R1111-ENG3	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
ACOMP	EU	60JJJJ-ENG3	CO	40 CFR Part 60, Subpart JJJJ	§ 60.4233(d) § 1048.101(c) § 60.4233(h) § 60.4234	Owners and operators of stationary non-emergency SI ICE with a maximum engine power greater than 19 KW	§ 60.4243(b)(2)(i) § 60.4243(e) § 60.4243(f) § 60.4244(a)	§ 60.4243(b)(2)(i) § 60.4243(e) § 60.4245(a)(1) § 60.4245(a)(2)	§ 60.4245(d)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4243(b) § 60.4243(b)(2) § 60.4243(b)(2)(i) § 60.4243(e) § 60.4243(g) § 60.4246	and less than 75 KW and ARE NOT severe-duty engines and were manufactured on or after 07/01/2008 must comply with a CO emission limit of 6.5 g/KW-hr, as stated in 40 CFR 1048.101(c).	§ 60.4244(b) § 60.4244(c) § 60.4244(e)	§ 60.4245(a)(4)	
ACOMP	EU	60JJJJ-ENG3	HC and NO <sub>x</sub>	40 CFR Part 60, Subpart JJJJ	§ 60.4233(d) § 1048.101(c) § 60.4233(h) § 60.4234 § 60.4243(b) § 60.4243(b)(2) § 60.4243(b)(2)(i) § 60.4243(e) § 60.4243(g) § 60.4246	Owners and operators of stationary non-emergency SI ICE with a maximum engine power greater than 19 KW and less than 75 KW and were manufactured on or after 07/01/2008 must comply with an HC+NO <sub>x</sub> emission limit of 3.8 g/KW-hr, as stated in 40 CFR 1048.101(c).	§ 60.4243(b)(2)(i) § 60.4243(e) § 60.4243(f) § 60.4244(a) § 60.4244(b) § 60.4244(c) § 60.4244(d)	§ 60.4243(b)(2)(i) § 60.4243(e) § 60.4245(a)(1) § 60.4245(a)(2) § 60.4245(a)(4)	§ 60.4245(d)
ACOMP	EU	63ZZZZ-ENG3	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
G-1	EP	R1111-ENG2	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						after January 31, 1972.			
G-1	EU	63ZZZZ-ENG2	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
LOAD	EU	R115-LOAD1	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(2)(A) [G]§ 115.212(a)(7) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Any plant, excluding gasoline bulk plants, which loads less than 20,000 gpd of VOC with a true vapor pressure of 0.5 psia or greater is exempt from the requirements of this division, except for the specified requirements.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B) § 115.216(3)(D)	None
LOAD-4A	EU	R115-LOAD5	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(2)(A) § 115.212(a)(2) [G]§ 115.212(a)(7) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Any plant, excluding gasoline bulk plants, which loads less than 20,000 gpd of VOC with a true vapor pressure of 0.5 psia or greater is exempt from the requirements of this division, except for the specified requirements.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B) § 115.216(3)(D)	None
TK-1	EP	R1111-TNK1	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(A)	Visible emissions from any stationary vent shall not exceed an opacity of 30% averaged over a six-minute period. The emissions from	None	None	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						this vent originate from colorless VOCs, non-fuming liquids, or other sources that are not capable of obstructing the transmission of light. These vents are not capable of exceeding the opacity standards of 30 TAC Chapter 111 and therefore no monitoring is required to demonstrate compliance.			
TK-1	EU	R115-TK1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
TK-2	EU	R115-TK2	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
TK-5	EU	R115-TK5	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
TK-6	EU	R115-TK6	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TK-7	EU	R115-TK7	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
TK-9	EU	R115-TK9	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None

**Additional Monitoring Requirements**

**Periodic Monitoring Summary ..... 22**

### Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 601	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-ENG1
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(A)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually or at any time an alternate fuel is used	
Averaging Period: n/a	
Deviation Limit: Fire alternative fuel other than natural gas alone or in combination with natural gas for greater than or equal to 24 consecutive hours; or visible emissions observed; or visible emissions greater than 30% opacity observed.	
<p>Periodic Monitoring Text: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, for a period greater than or equal to 24 consecutive hours it shall be considered and reported as a deviation or the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are observed. Any time an alternate fuel is fired for a period of greater than 7 consecutive days then visible emissions observations will be conducted no less than once per week. Documentation of all observations shall be maintained. If visible emissions are present during the firing of an alternate fuel, the permit holder shall either list this occurrence as a deviation or the permit holder may determine the opacity consistent with Test Method 9. Any opacity readings that are above the opacity limit from the underlying applicable requirement shall be reported as a deviation.</p>	



### Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 602	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-ENG1
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(A)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually or at any time an alternate fuel is used	
Averaging Period: n/a	
Deviation Limit: Fire alternative fuel other than natural gas alone or in combination with natural gas for greater than or equal to 24 consecutive hours; or visible emissions observed; or visible emissions greater than 30% opacity observed.	
<p>Periodic Monitoring Text: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, for a period greater than or equal to 24 consecutive hours it shall be considered and reported as a deviation or the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are observed. Any time an alternate fuel is fired for a period of greater than 7 consecutive days then visible emissions observations will be conducted no less than once per week. Documentation of all observations shall be maintained. If visible emissions are present during the firing of an alternate fuel, the permit holder shall either list this occurrence as a deviation or the permit holder may determine the opacity consistent with Test Method 9. Any opacity readings that are above the opacity limit from the underlying applicable requirement shall be reported as a deviation.</p>	

### Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 603	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-ENG1
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(A)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually or at any time an alternate fuel is used	
Averaging Period: n/a	
Deviation Limit: Fire alternative fuel other than natural gas alone or in combination with natural gas for greater than or equal to 24 consecutive hours; or visible emissions observed; or visible emissions greater than 30% opacity observed.	
<p>Periodic Monitoring Text: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, for a period greater than or equal to 24 consecutive hours it shall be considered and reported as a deviation or the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are observed. Any time an alternate fuel is fired for a period of greater than 7 consecutive days then visible emissions observations will be conducted no less than once per week. Documentation of all observations shall be maintained. If visible emissions are present during the firing of an alternate fuel, the permit holder shall either list this occurrence as a deviation or the permit holder may determine the opacity consistent with Test Method 9. Any opacity readings that are above the opacity limit from the underlying applicable requirement shall be reported as a deviation.</p>	

### Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: ACOMP	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-ENG3
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually or at any time an alternate fuel is used	
Averaging Period: n/a	
Deviation Limit: Fire alternative fuel other than natural gas alone or in combination with natural gas for greater than or equal to 24 consecutive hours; or visible emissions observed; or visible emissions greater than 20% opacity observed.	
<p>Periodic Monitoring Text: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, for a period greater than or equal to 24 consecutive hours it shall be considered and reported as a deviation or the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are observed. Any time an alternate fuel is fired for a period of greater than 7 consecutive days then visible emissions observations will be conducted no less than once per week. Documentation of all observations shall be maintained. If visible emissions are present during the firing of an alternate fuel, the permit holder shall either list this occurrence as a deviation or the permit holder may determine the opacity consistent with Test Method 9. Any opacity readings that are above the opacity limit from the underlying applicable requirement shall be reported as a deviation.</p>	

### Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: G-1	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-ENG2
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually or at any time an alternate fuel is used	
Averaging Period: n/a	
Deviation Limit: Fire alternative fuel other than natural gas alone or in combination with natural gas for greater than or equal to 24 consecutive hours; or visible emissions observed; or visible emissions greater than 20% opacity observed.	
<p>Periodic Monitoring Text: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, for a period greater than or equal to 24 consecutive hours it shall be considered and reported as a deviation or the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are observed. Any time an alternate fuel is fired for a period of greater than 7 consecutive days then visible emissions observations will be conducted no less than once per week. Documentation of all observations shall be maintained. If visible emissions are present during the firing of an alternate fuel, the permit holder shall either list this occurrence as a deviation or the permit holder may determine the opacity consistent with Test Method 9. Any opacity readings that are above the opacity limit from the underlying applicable requirement shall be reported as a deviation.</p>	

**Permit Shield**

**Permit Shield ..... 28**

### Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
601	N/A	40 CFR Part 60, Subpart JJJJ	Construction commenced prior to June 12, 2006.
602	N/A	40 CFR Part 60, Subpart JJJJ	Construction commenced prior to June 12, 2006.
603	N/A	40 CFR Part 60, Subpart JJJJ	Construction commenced prior to June 12, 2006.
ACOMP	N/A	30 TAC Chapter 117, Subchapter B	Unit is a stationary combustion engine rated less than 300 hp.
FUG	N/A	40 CFR Part 60, Subpart KKK	The facility is not a natural gas processing plant as defined in 40 CFR 60.631.
G-1	N/A	30 TAC Chapter 117, Subchapter B	Unit was placed in service after November 15, 1992 and is not a functionally identical replacement for an existing unit.
G-1	N/A	40 CFR Part 60, Subpart JJJJ	Emergency engine greater than 25 hp, manufactured prior to January 1, 2009.
LOAD-4A	N/A	30 TAC Chapter 115, Loading and Unloading of VOC	Emission unit is a motor vehicle fuel dispensing facility.
PCLEAN1	N/A	30 TAC Chapter 115, Degreasing Processes	EU is a remote reservoir cold solvent cleaner which uses solvent with a true vapor pressure equal to or < 0.6 psia measured at 100 F and which has a drain area < 16 in <sup>2</sup> and who properly disposes of waste solvent in enclosed containers.
PCLEAN1	N/A	40 CFR Part 63, Subpart T	The solvent cleaning machine does not use solvent containing methylene chloride, perchloroethylene, trichloroethylene, 1,1,1-trichloroethane, carbon tetrachloride or chloroform, or any combination of these halogenated HAP solvents.
TK-1	N/A	40 CFR Part 60, Subpart K	Tank was constructed prior to June 11, 1973 and has not been modified.
TK-2	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters (19813 gallons).
TK-3	N/A	30 TAC Chapter 115, Storage of VOCs	Tank capacity is less than 1000 gallons.

### Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
TK-3	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters (19813 gallons).
TK-4	N/A	30 TAC Chapter 115, Storage of VOCs	Tank capacity is less than 1000 gallons.
TK-4	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters (19813 gallons).
TK-5	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters (19813 gallons).
TK-6	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters (19813 gallons).
TK-7	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters (19813 gallons).
TK-8	N/A	30 TAC Chapter 115, Storage of VOCs	Tank capacity is less than 210,000 gallons and stores only condensate prior to custody transfer.
TK-8	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 1589.874 cubic meters (420,000 gallons) and stores only condensate prior to custody transfer.
TK-9	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters (19813 gallons).

**New Source Review Authorization References**

<b>New Source Review Authorization References .....</b>	<b>31</b>
<b>New Source Review Authorization References by Emission Unit .....</b>	<b>32</b>



### New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Title 30 TAC Chapter 116 Permits, Special Permits, and Other Authorizations (Other Than Permits By Rule, PSD Permits, or NA Permits) for the Application Area.	
Authorization No.: 55849	Issuance Date: 07/28/2017
Permits By Rule (30 TAC Chapter 106) for the Application Area	
Number: 106.359	Version No./Date: 09/10/2013
Number: 106.511	Version No./Date: 09/04/2000
Number: 66	Version No./Date: 10/04/1995
Number: 107	Version No./Date: 10/04/1995

### New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
601	2000 HP COMPRESSOR ENGINE 1	55849
602	2000 HP COMPRESSOR ENGINE 2	55849
603	2000 HP COMPRESSOR ENGINE 3	55849
ACOMP	68 HP ARROW VRG 330 AIR COMPRESSOR ENGINE	55849
FUG	PIPING COMPONENT FUGITIVES	55849
G-1	454 HP GENERAC EMERGENCY GENERATOR	106.511/09/04/2000
LOAD-4A	GASOLINE UNLOADING POINT	66/10/04/1995
LOAD	CONDENSATE LOADING POINT	55849
PCLEAN1	REMOTE RESERVOIR DEGREASER	107/10/04/1995
TK-1	6000 GAL LUBE OIL TANK	55849
TK-2	1748 GAL USED OIL TANK	55849
TK-3	500 GAL GASOLINE TANK	66/10/04/1995
TK-4	500 GAL DIESEL TANK	66/10/04/1995
TK-5	8820 GAL SLOP OIL TANK	55849
TK-6	8820 GAL OILY WATER TANK	55849
TK-7	8820 GAL OILY WATER TANK	55849
TK-8	8820 GAL CONDENSATE TANK	55849
TK-9	4620 GAL ENGINE WATER JACKET DRAIN TANK	55849

**Appendix A**

**Acronym List ..... 34**

## Acronym List

The following abbreviations or acronyms may be used in this permit:

ACFM .....	actual cubic feet per minute
AMOC .....	alternate means of control
ARP .....	Acid Rain Program
ASTM .....	American Society of Testing and Materials
B/PA .....	Beaumont/Port Arthur (nonattainment area)
CAM .....	Compliance Assurance Monitoring
CD .....	control device
CEMS .....	continuous emissions monitoring system
CFR .....	Code of Federal Regulations
COMS .....	continuous opacity monitoring system
CVS .....	closed vent system
D/FW .....	Dallas/Fort Worth (nonattainment area)
EP .....	emission point
EPA .....	U.S. Environmental Protection Agency
EU .....	emission unit
FCAA Amendments .....	Federal Clean Air Act Amendments
FOP .....	federal operating permit
gr/100 scf .....	grains per 100 standard cubic feet
HAP .....	hazardous air pollutant
H/G/B .....	Houston/Galveston/Brazoria (nonattainment area)
H <sub>2</sub> S .....	hydrogen sulfide
ID No. ....	identification number
lb/hr .....	pound(s) per hour
MACT .....	Maximum Achievable Control Technology (40 CFR Part 63)
MMBtu/hr .....	Million British thermal units per hour
NA .....	nonattainment
N/A .....	not applicable
NADB .....	National Allowance Data Base
NESHAP .....	National Emission Standards for Hazardous Air Pollutants (40 CFR Part 61)
NO <sub>x</sub> .....	nitrogen oxides
NSPS .....	New Source Performance Standard (40 CFR Part 60)
NSR .....	New Source Review
ORIS .....	Office of Regulatory Information Systems
Pb .....	lead
PBR .....	Permit By Rule
PEMS .....	predictive emissions monitoring system
PM .....	particulate matter
ppmv .....	parts per million by volume
PRO .....	process unit
PSD .....	prevention of significant deterioration
psia .....	pounds per square inch absolute
SIP .....	state implementation plan
SO <sub>2</sub> .....	sulfur dioxide
TCEQ .....	Texas Commission on Environmental Quality
TSP .....	total suspended particulate
TVP .....	true vapor pressure
U.S.C. ....	United States Code
VOC .....	volatile organic compound